

SECTION 6

6.26 VALVE AND METER SUPPORTS:

Meter supports shall be a solid concrete block as shown on Sheets 51, 52, 56, and 58 of the Standard Drawings. Fabricated metal supports shall be used to support valves 4 inches and larger and shall conform to Sheets 37, 56, 58, 71, and 73, of the Standard Drawings.